

FIRE RANGERS

P.No.18, 13 /A, Ring Road, Belavadi Industrial Area,
MYSORE - 570 018

FR/AV/2020-21/119.

07/10/2020.

CERTIFICATE

This is to certify that, **M/s FIRE RANGERS**, Mysore, have undertaken up the periodical maintenance work pertaining to refilling and servicing of fire extinguishers which are installed at "**ADHICHUNCHUNAGIRI VIDYAPEETA**", **Near Apollo Hospital, Kuvempunagara, Mysore.**

We state that, the said education institution has taken precautions of fire accidents. The fire extinguishers were supplied us in the earlier years and extinguishers are of IS standard 15863 having ISI Marks.

The following fire extinguishers are duly refilled and serviced by us as per I.S.Norms on dated 07-10-2020.

- | | |
|---|---------|
| 01. ABC type 4kg capacity fire extinguisher | -05Nos. |
| 02. Carbon Dioxide 2kg capacity fire extinguisher | -01No. |

The above mentioned fire extinguishers of the said education institution are fit for use on date, and valid from 07th October 2020 to 06th October 2021.



For Fire Rangers